




SOUND ABSORPTION AREA FOR OBJECT

Measured and evaluated according to ISO 354 and ISO 20189

| | | | |
|-------------------|-----------|---------|---------|
| Client: | Abstracta | | |
| Object: | Vika lamp | | |
| Size [mm]: | w = 1500 | h = 155 | d = 283 |

| Octave band (Hz) | Equivalent sound absorption area / unit (m ² Sabine) |
|------------------------------|---|
| 63 | |
| 125 | 0.04 |
| 250 | 0.24 |
| 500 | 0.52 |
| 1000 | 0.7 |
| 2000 | 0.91 |
| 4000 | 0.8 |
| N₁₀ = 19.2 | |



| | |
|-----------------------------|-----------------------|
| ORIGINAL TEST REPORT | DATE OF REPORT |
| 20231213.8 | 2023-12-18 |

