

REACTION TO FIRE

Applicant:

FIELTROS Y TEJIDOS IND., S.L.

Orient, 78-84 2ª Planta. Oficina: 16-17 ES-08172 SANT CUGAT DEL VALLÈS Barcelona

Is authorized to place the label "Classification of Reaction to Fire of Construction Products" according to the 2024AN0120.



CLASSIFICATION OF REACTION TO FIRE OF: CONSTRUCTION PRODUCTS

Nº: 24AN0120

The sample referenced as:

"TEXFEL INTERIORS 500"



has been tested according to the standards test by range of "13" needled nonwoven fabrics of which the colors have been tested; gray 400 ML, orange 426 ML and gray 496 ML. The classification according to standard EN 13501-1:2018 is:

"B-s1,d0"



Date of Issue

26th of January 2024

Celia Dolçà Head of Fire Behaviour lab.

Plaza Emilio Sala, 1 · Alcoy (Alicante) 965542200 · info@aitex.es www.aitex.es